



Certificate of Compliance

This certificate is issued for the following:

INDICATING BUTTERFLY VALVES

Model 107F – Wafer Style
Model 111F – Grooved End
(per table below)

Prepared for:

Hakohav Valves Industries
8 Hashlagan St
Industrial Zone
Kiryat Gat, 82021
Israel

Manufactured at:

Hakohav Valves Industries
8 Hashlagan St
Industrial Zone
Kiryat Gat, 82021
Israel

FM Approvals Class: 1112, *Indicating Valves (Ball and Butterfly Type)*

Approval Identification: 0003033679

Approval Granted: February 24, 2012

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group



Certificate of Compliance

Model Number	Product Type	Nominal Pipe Size, inch (mm)	Rated Working Pressure, psi (kPa)	Remarks
107F	Butterfly Valve, Wafer Style	2, 2-1/2, 3, 4, 6, 8	175 (1205)	a, b, c
111F	Butterfly Valve, Grooved Ends	3, 4, 6, 8	175 (1205)	a, b, c

Remarks:

- a. Available with dual supervisory switches.
- b. FM Approved for indoor and outdoor service.
- c. FM Approved for aboveground installations only.



Member of the FM Global Group